



**Bureau Veritas Consumer
Product Services GmbH**

Businesspark A96
86842 Türkheim
Germany
+ 49 (0) 8245 96810-0
cps-tuerkheim@de.bureauveritas.com

Certificate of compliance

Applicant: SolarEdge Technologies Ltd.
Abba Eban 1a
Hertzlia 46725
Israel

Product: Automatic disconnection device between a generator
and the public low-voltage grid

Model: SE3300; SE4000; SE5000; SE6000

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with AS 4777.2:2005 and AS 4777.3:2005 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied rules and standards :

AS 4777.2:2005 Grid connection of energy systems via inverters, Part 2: Inverter requirements
AS 4777.3:2005 Grid connection of energy systems via inverters, Part 3: Grid protection requirements

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate of valid safety specifications for the specified use in accordance with regulations, excluding AS 3100:2002.

Report number: 09TH0001-AS4777

Certificate number: U10-017

Date of issue: 2010-01-19

Valid until:

2013-01-19

Andreas Aufmuth