



**Bureau Veritas Consumer  
Products Services  
Germany GmbH**

Businesspark A96  
86842 Türkheim  
Germany  
+ 49 (0) 40 74041 - 0  
cps-tuerkheim@de.bureauveritas.com

## Certificate of compliance

**Applicant:** **SolarEdge Technologies Ltd.**  
6 HeHarash St.  
Hod Hasharon 45240  
**Israel**

**Product:** **Automatic disconnection device between a generator  
and the public low-voltage grid**

**Model:** **SE3000; SE3300; SE3500; SE4000; SE5000; SE6000**

**Use in accordance with regulations:**

Automatic disconnection device with single-phase mains surveillance in accordance with AS 4777.2:2005 and AS 4777.3:2005 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

**Applied rules and standards :**

AS 4777.2:2005 Grid connection of energy systems via inverters, Part 2: Inverter requirements  
AS 4777.3:2005 Grid connection of energy systems via inverters, Part 3: Grid protection requirements

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate of valid safety specifications for the specified use in accordance with regulations, excluding AS 3100:2002.

**Report number:** **09TH0001-AS4777**

**Certificate number:** **U11-372**

**Date of issue:** **2011-05-06**

**Valid until:**

**2014-05-05**

Achim Hänchen